INFORMAL TENDER ADVERT

NELSON MANDELA BAY MUNICIPALITY
BUDGET AND TREASURY DIRECTORATE
PURCHASING AND STORES DIVISION

Tender Number: GQ11266578
Buyer: Senekal, Miss E [00012850]

Closing Date: 2026-11-24
Closing Time: 11:00 A.M

Telephone : 041 506 7630

REFER ALL ENQUIRIES TO THE BUYER

ITEM	QUANTITY	UNIT	KEY WORD	DESCRIPTION	REQUISITION
1	20.00	EACH	HIGH PRESSURE FIRE FIGHTING HOSE 19MM	Supply and Delivery of 19mm High Pressure Fire Fighting Hose for Off Road Appliances as per Uploaded Specification on Informal Tender Website Tenders will be further evaluated only if they meet the minimum requirements stated below: Brand name of item quoted must be stated on informal tender quote with submission on electronic system Failure to meet the minimum requirement will deem the tender non-responsive Brochure/ sample of item may be requested from shortlisted tenderers, and needs to be provided within 72 hrs, failure to provide excludes from further consideration. For further information contact Mr L Linde @ 041-5085559.	AA178823
2	20.00	EACH	SERVICE OF SCBA FACEPIECE	Tenders are invited for Inspection and Service of SCBA Facepiece as per Uploaded Specification on informal tender website. Tenderers will be further evaluated only if they meet the minimum requirements stated below: Brand name of item quoted must be stated on informal tender quote with submission on electronic system. Failure to meet the minimum	AA178826

THE FOLLOWING CONDITIONS APPLY TO THIS INFORMAL TENDER

- BEFORE COMPLETING THIS FORM, SERVICE PROVIDERS MUST STUDY THE GENERAL CONDITIONS, DEFINITIONS AND DIRECTIVES APPLICABLE IN RESPECT OF SPECIFIC GOALS, AS PRESCRIBED IN THE PREFERENTIAL PROCUREMENT REGULATION OF 2022 THE 80/20 SYSTEM APPLIES TO THIS TENDER.
- Acceptance of this tender submission is subject to the General Conditions of Tender and Conditions of Purchase
- Acceptance of this tender is subject to successful registration on the Nelson Mandela Bay Supplier Database.
- For further information to register, please call Compliance Section @ 041 506 3274
- Failure to comply with these conditions may invalidate your tender submission.
- All tender prices should be valid for a minimum period of thirty (30) days from date of tender.
- ALL TENDER RESPONSES SHOULD BE COMPLETED ONLINE AND NO FAX SUBMISSION WILL BE ACCEPTED BY SUPPLY CHAIN UNIT.

				requirement will deem the tender non-resonsive. Brochure/ Sample of item may be requested from shortlisted tenderers, and needs to be supplied within 72hrs, failure to provide excludes from further consideration. For further information contact Mr L Linde @ 041-5085559	
3	20.00	EACH	HIGH PRESSURE HOSE	Tenders are invited for Supply and Delivery High Pressure Hose for Offroad Appliances as per Uploaded Specification on Informal Tender Website or available at SCM, Harrower Road , Gqeberha. Tenders will be further evaluated only if they meet the minimum requirements stated below: Brand name of item quoted must be stated on informal tender quote with submission on electronic system Failure to meet the minimum requirement will deem the tender non-responsive Brochure/ sample of item may be requested from shortlisted tenderers, and needs to be provided within 72 hrs, failure to provide excludes from further consideration. For further information contact Mr L Linde @ 041-5085559.	AA178828

THE FOLLOWING CONDITIONS APPLY TO THIS INFORMAL TENDER

- BEFORE COMPLETING THIS FORM, SERVICE PROVIDERS MUST STUDY THE GENERAL CONDITIONS, DEFINITIONS AND DIRECTIVES APPLICABLE IN RESPECT OF SPECIFIC GOALS, AS PRESCRIBED IN THE PREFERENTIAL PROCUREMENT REGULATION OF 2022 THE 80/20 SYSTEM APPLIES TO THIS TENDER.
- Acceptance of this tender submission is subject to the General Conditions of Tender and Conditions of Purchase
- Acceptance of this tender is subject to successful registration on the Nelson Mandela Bay Supplier Database.
- For further information to register, please call Compliance Section @ 041 506 3274
- Failure to comply with these conditions may invalidate your tender submission.
- All tender prices should be valid for a minimum period of thirty (30) days from date of tender.
- ALL TENDER RESPONSES SHOULD BE COMPLETED ONLINE AND NO FAX SUBMISSION WILL BE ACCEPTED BY SUPPLY CHAIN UNIT.

AA 178823

SPECIFICATION

19 MM HIGH PRESSURE FIRE FIGHTING HOSE FOR OFF-ROAD APPLIANCES

This specification covers the requirements for heavy-duty high-pressure fire-fighting hose.

DIMENSIONS

Length	:	15 metres
Diameter	:	20mm Nominal (19.0 Actual)

CONSTRUCTION

1 Wire Braid Hose (DIN 20022 1SN SAE 100 R1 Type A)

Hose Max Operating Pressure	:	10500 kPa
Hose Min Burst Pressure	:	4200 kPa

COUPLINGS

Hermaphrodite Storz **Swivel** Light Alloy Couplings Crimped on with Collars.

No Sharp Edges to protrude from Fittings.

COMPLIANCE

A short sample length of hose fitted with specified couplings to be submitted for approval on request.

Tenderers will be further evaluated only if they meet the minimum requirements stated below:

- Brand name of item quoted must be stated on informal tender quote with submission on electronic system.
- Failure to meet the minimum requirement will deem the tender non-responsive
- Brochure / Sample of item may be requested from shortlisted tenderers, within 72 hours, failure to provide excludes from further consideration.

AA178826

SPECIFICATION

INSPECTION & SERVICE OF SCBA FACEPIECE

This specification covers the requirement for the inspection, service and repair for the breathing apparatus facepieces currently in service with the NMBM Fire & Rescue Services.

SCOPE OF WORK:

The following scope of work shall apply:

1. The facepieces components replaced shall be of the same make or equal, brand and model as those currently in service with the NMBM Fire & Rescue Services.
2. The work shall be carried out by an accredited service agent of the manufacture.
3. The accredited service agent is required to be SANAS registered and fully compliant with OHS Act 1993 and National Regulator Act 2008, Compulsory Specifications.
4. Completed work shall be tested prior to dispatch and a test certificate is to be provided in accordance with the service applicable requirements specific to such manufacturer.
5. The successful tenderer is required to collect the SCBA facepieces from the South End Fire Station and return them on completion of the work as specified.

FACEPIECE COMPONENT INSPECTION:

The following scope of inspection and possible replacement shall include the following:

1.1 **Body**
Check sealing edges and head harness for damage. .

1.2 **Nose Cup**
The nose cup is easily removed or replaced without the use of tools, for ease of cleaning and disinfecting. Check for damage.

1.3 **Lens**
The effective field of vision shall be a minimum of 96%.

1.4 **Lens Frame**
Check lens frame screws and nuts for quick and easy lens replacement.

1.5 **Speech Diaphragm**

1.6 **Exhalation Valve**
The exhalation valve cover and exhalation valve can be easily removed without the use of special tools for ease of cleaning and decontamination.

1.7 **Head Harness**
The head harness straps are easily removable without the use of tools.

AA178826

Tenderers will be further evaluated only if they meet the minimum requirements stated below:

- Brand name of item quoted must be stated on informal tender quote with submission on electronic system.
- Failure to meet the minimum requirement will deem the tender non-responsive
- Brochure / Sample of item may be requested from shortlisted tenderers, within 72 hours, failure to provide excludes from further consideration.

Specification

High pressure hose for offroad appliances

Scope:

This specification covers the requirements for high pressure hose for offroad appliances.

High pressure hose specification:

20 meters CPS-002-08 rat 2 wire hose ½" 12.70mm

Key features

Reinforcement: Two braids of high tensile steel wire.

Inner Diameter: ½ inch or 12.7mm.

Working pressure: 275B.

Burst pressure:1,100B.

Outer Diameter: 20.9 to 22.2 mm.

Temperature Range: -40°C to 100°C.

Cover: Synthetic rubber, resistant to abrasion, oil and water.

Coupling to be fitted on the hoses:

CP 10161-08 XTCL-08

CP 100-0808-X08NM08

CP10212-08F-QRF-08BF Coupler.

Tenders will be further evaluated only if they meet the minimum requirements stated below:

- Brand name of item quoted must be stated on informal tender quote with submission on electronic system.
- Failure to meet the minimum requirement will deem the tender non-responsive.
- Brochure/ Sample of item may be requested from shortlisted tenderers, within 72 hours, failure to provide excludes from further consideration.